



November 4, 2019

Subject: Invitation to Bid# 2019-TH-01: Low Voltage, Access Control, and CCTV Contractor for the Town's new Municipal Building – Addendum 4

Ladies and Gentlemen,

The purpose of this addendum is to address a question that a potential bidder asked.

The question: "Is the contractor to provide all electronic locksets? Or are electronic locks provided by the door hardware contractor?"

The Contractor's response: "The door hardware sub will provide the strike, but not the card reader or low voltage cabling. I will get with [the estimator] and ensure we have this covered on our end."

Received by: _____ Company: _____

Note: Please sign and return this addendum with your sealed bid. Any responder failing to return a signed addendum will still be responsible for complying with these requirements.

Respectfully,

Brandon Perkins
Town Manager

Incorporated 1911